


SECTION C-C

STANDARD SIDE ENTRY PIT

SCALE 1:40

NOTES:

1. ALL STEP IRONS TO BE HOT DIPPED GALVANISED AFTER FABRICATION.
2. STEP IRONS TO BE USED WHEN THE DISTANCE BETWEEN THE MANHOLE BASE AND FINISHED GROUND LEVEL EXCEEDS 1.0m.
3. ALL COMPONENTS TO BE DESIGNED TO ACCEPT A14 LOADING N.A.A.S.R.A. STANDARD.
4. ALL BASES TO BE BEDDED ON FIRM NATURAL OR COMPACTED SAND.
5. MORTAR TO BE 3 : 1 SAND : CEMENT MIXTURE.
6. INSITU CONCRETE TO HAVE MINIMUM STRENGTH OF 20 MPa AT 28 DAYS.
7. MANHOLES SHALL BE INTERLOCKING JOINT, EQUIVALENT TO 'CLASS S' PIPE.
8. ALL REINFORCEMENT AND STEEL TO BE CLEAN AND FREE FROM OIL, RUST AND OTHER DELETORIOUS SURFACE COATINGS.

AMENDMENTS		SHIRE OF BROOME WELD ST. (P.O. BOX 44) BROOME W.A. 6725		Survey -	Scale AS SHOWN	 <p>Shire of Broome people • place • prosperity</p>	Sheet No. 2 of 3	
No	DATE	PC	JW	Design JW	AutoCAD Ref: S00-005		<p>SIDE ENTRY PIT STANDARD DETAILS</p>	Drawing Number
		BY	APP'D	Drawn DS Checked JW	CivilCAD Ref: -			<p>S09-004</p>
				Contour Interval -	Approved			
				Date 23-9-09				